

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 2520-1701:0100 Page 1 of 1

**CATEGORY:** 2520 -- TREATED LUMBER

**LISTEE:** HOOVER TREATED WOOD PRODUCTS, INC. 154 WIRE ROAD, THOMSON, GA 30824  
Contact: Chris Athari (706) 755-5350 Fax (706) 595-6600  
Email: cathari@frtw.com

**DESIGN:** Treated Lumber with EXTERIOR FIRE X. Products are pressure impregnated with "EXTERIOR FIRE X" fire retardant chemical. EXTERIOR FIRE X covers the following types of lumber: Douglas Fir, Southern Yellow Pine, Western Red Cedar, and Redwood Lumber. Refer to listee's printed installation instructions for additional detailed product description and constructions.

**RATING:** Douglas Fir: 15 Flame Spread; 30 Smoke Developed  
Southern Yellow Pine: 15 Flame Spread; 50 Smoke Developed  
Western Red Cedar: 10 Flame Spread; 30-105 Smoke Developed  
Redwood: 10 Flame Spread; 10-115 Smoke Developed

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, product identification, classification, and Underwriter's Laboratory label.

**APPROVAL:** Listed as exterior type fire retardant treated lumber. Also approved for use as ignition resistant materials as specified in Chapter 7A of the \*California Building Code. The lumber must be pressure treated with the fire retardant chemical at the factory under authorized service inspection.

Corrected 9-25-12 il



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2019**

Listing Expires **June 30, 2020**

Authorized By: **DAVID CASTILLO**, Program Coordinator  
Fire Engineering Division